

## Annexure C

### PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 3873/ A3/ 2025

Dated.13.06.2025

It is certified that an inspection team headed by A.G.Rajan, Block Health Supervisor from Govt. Primary Health Centre, Elizhur inspected the **M/S. N.S.N.MEMORIAL SCHOOL, PKV MAHA NAGAR MAIN ROAD, DHARMALINGAM NAGAR, CHENNAI- 600 069, KUNDRATHUR TALUK, KANCHEEPURAM DISTRICT** on 10.06.2025 on the basis of Water Test Report **No.TC14166250000617F/Doc.No.CMWSSBFRM/7.8/01** dt **05.06.2025** of Chennai Metropolitan Water Supply Water and Waste Water Testing Laboratory Quality Assurance Wing, No.1, New Avadi Road, Kilpauk, Chennai-600010 found that the **M/S. N.S.N.MEMORIAL SCHOOL** has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ UT. Govt.

The above Certificate is valid for a period of **ONE YEAR**

*A.G. Rajan*  
**BLOCK HEALTH SUPERVISOR**  
**GOVERNMENT PRIMARY HEALTH CENTRE**  
**EZHICHUR - 603204**  
**KUNDRATHUR BLOCK**  
**KANCHEEPURAM DISTRICT**

Countersigned

Signature with Seal:

*Q-13/6/25*  
**District Health Officer**  
**Kancheepuram District**

Name : A.G.Rajan  
Designation : Block Health Supervisor  
Name & Address : Govt. Primary Health of  
the Office : Centre, Elizhur,  
Kundrathur Block,  
Kancheepuram District

To

**M/S. N.S.N.MEMORIAL SCHOOL,**  
PKV Maha Nagar Main Road,  
Dharmalingam Nagar,  
Chennai- 600 069.  
Kundrathur Taluk,  
Kancheepuram District.



CHENNAI METROPOLITAN WATER SUPPLY  
WATER AND WASTE WATER TESTING LABORATORY  
QUALITY ASURANCE WING, No.1, NEW AVADI ROAD,  
KILPAUK, CHENNAI – 600010.



ULR No : TC14166250000617F TEST REPORT - DRINKING WATER Doc.No: CMWSSB/FRM/7.8/01

Report No: TR/2025/617-01 Report Issue Date: 05-06-2025 Page No 1 of 3  
Challan No: 85 Challan Date: 30-05-2025 Amount (Rs) 2596/-

Client Name & Address & Contact No / Email.ID : NSN Memorial School,  
P.K.V. Maha Nagar  
Kundrathur  
Chennai - 69

Sample Name : Water Sample Description : Drinking water  
Sample Number : 617 Sample Container : Jerry Can  
Sample Submitted by : Customer Location & Date : RO Water-30-05-2025  
Sample Quantity : 2Litres Sample Condition : Good  
Sample Received On : 30-05-2025 Environmental Condition : 23.0°C – 27.0°C  
Test Commenced on : 30-05-2025 Test Completed on : 02-06-2025

S. No	Parameters	Unit	Test Method	Result	Specification as per IS 10500-2012	
					Acceptable Limit	Permissible Limit
1	Colour	CU	IS 3025: Part 4: 2021	2	5	15
2	Odour	--	IS 3025: Part 5: 2018	Agreeable	Agreeable	Agreeable
3	Turbidity	NTU	IS 3025: Part 10: 2023	0.4	1	5
4	pH @ 25°C	--	IS 3025: Part 11: 2022	7.23	6.5 To 8.5	6.5 To 8.5
5	Electrical Conductivity @25°C	µS/cm	IS 3025: Part 14: 2013(RA 2023)	102	-	-
6	Total Dissolved Solids	mg/L	IS 3025: Part 16: 2023	66	500	2000
7	Total Hardness as CaCO <sub>3</sub>	mg/L	IS 3025: Part 21: 2009(RA 2023)	27	200	600
8	Calcium as Ca	mg/L	IS 3025: Part 40: 2024	6	75	200
9	Magnesium as Mg	mg/L	IS 3025: Part 46: 2023	BLQ(LOQ:5)	30	100
10	Chloride as Cl	mg/L	IS 3025: Part 32: 1988(RA 2019)	14	250	1000


M. Sudh 05/06/25  
Reviewed by  
Water Analyst

S.Chitra 05/06/25  
Authorised Signatory  
S.Chitra Water Analyst

Note:

- The test results relate only to the items tested. & The result applied to the sample as received basis.
- The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
- Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.





CHENNAI METROPOLITAN WATER SUPPLY  
WATER AND WASTE WATER TESTING LABORATORY  
QUALITY ASURANCE WING, No.1, NEW AVADI ROAD,  
KILPAUK, CHENNAI – 600010.



ULR No : TC14166250000617F TEST REPORT - DRINKING WATER Doc.No: CMWSSB/FRM/7.8/01

Report No: TR/2025/617-01 Report Issue Date: 05-06-2025 Page No: 2 of 3  
Challan No: 85 Challan Date: 30-05-2025 Amount (Rs): 2596/-

S. No	Parameters	Unit	Test Method	Result	Specification as per IS 10500:2012	
					Acceptable Limit	Permissible Limit
11	Total alkalinity as CaCO <sub>3</sub>	mg/L	IS 3025: Part 23: 2023	34	200	600
12	Chlorine, Residual	mg/L	IS 3025: Part 26: 2021	BLQ(LOQ:0.2)	0.2	1.0
13	Ammonia as N	mg/L	IS 3025: Part 34: 1988(RA 2019)	BLQ(LOQ:0.1)	0.5	No Relaxation
14	Nitrite as NO <sub>2</sub>	mg/L	IS 3025: Part 34: 2019(RA 2019)	0.02	-	-
15	Fluoride as F	mg/L	IS 3025: Part 60: 2008(RA 2019)	BLQ(LOQ:0.2)	1.0	1.5
16	Sulphate as SO <sub>4</sub>	mg/L	IS 3025: Part 24: Sec 1: 2022	5	200	400
17	Iron as Fe	mg/L	IS 3025: Part 53: 2024	0.11	0.3	No Relaxation

---Contd---

Reviewed by  
Water Analyst

Authorised Signatory  
S.Chitra Water Analyst

Note:

- The test results relate only to the items tested. & The result applied to the sample as received basis.
- The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
- Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.